

Example of simple program for elevator control with LIFT2 interface (X=1-36):

Type R1 - R36: General


```

Event ReaderX.Valid
Relay1=On
Delay(Par1)
Relay1=Off
EventEnd
    
```

Elevator control:
 When a user encloses card to the reader, the outputs of all enabled floors are set for pre-defined time (Par1 parameter). Pushing the floor button during this period starts moving the elevator to selected floor.

Note: Advantage of this solution is the simplicity, disadvantage is the loss of information about target floor.

WREM 61 (R10, ProxPoint Plus...)



ELEVATOR

